



**COMPANIA DE UTILITĂȚI PUBLICE
DUNĂREA BRĂILA**
ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1
Tel.: 40-239-692900 ; Fax: 40-239-693209
J09/215/14.03.1995/; C.F.:RO7179966/10.04.1995
www.apabraila.ro; e-mail:dunarea@apabraila.ro



Certificat nr. 730C ISO 9001
Certificat nr. 388M ISO 14001
Certificat nr. 006AM ISO 37001
Certificat nr. 269HS OHSAS 18001

**PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE BRAILA
MAI 2021**

Denumire indicatori de calitate	UM	Valori obtinute													Limite admise conform Legii 458/2002 republicata	
		Punct de recoltare nr.														
		1	2	3	4	5	6	7	8	9	10	11	12	13		
		Gara CFR	Panait Istrati	Concordia	Cart. Obor	Cart. Viziru III	Loc. Comaneasca	Loc. Scortaru Vechi	Loc. Tudor Vladimirescu	Loc. Lacu Sarat	Loc. Chiscani	Loc. Muchea	Loc. Martacesti	Loc. Silistea		
PH	unit de pH	7.9	7.9	7.8	7.8	7.8	7.9	7.8	7.9	7.9	7.8	8.1	8.1	8	6.5 ÷ 9.5	
Conductivitate	μS/cm	426	426	422	429	428	429	430	427	431	425	438	439	436	≤ 2500	
Turbiditate	grade NTU	0.64	0.60	0.48	0.42	0.56	<0.3	<0.3	0.39	0.34	<0.3	0.76	0.50	0.54	≤ 5	
Clor rezidual liber	mg/l	0.50	0.40	0.46	0.35	0.20	0.20	0.36	0.17	0.17	0.45	0.14	0.24	0.20	≥0.1 ÷ ≤0.5	
Oxidabilitate	mgO2/l	1.43	1.31	1.30	1.43	1.30	1.17	1.23	1.23	1.23	1.17	1.24	1.11	1.11	≤ 5	
Aluminiu	μg/l	90	85	87	91	84	76	76	81	75	86	102	104	105	≤ 200	
Amoniu	mg/l	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	≤ 0.5	
Nitrati	mg/l	3.380	3.816	3.667	4.346	3.840	4.151	4.048	4.408	4.072	5.111	3.782	3.410	3.686	≤ 50	
Nitriti	mg/l	<0.040	<0.040	<0.040	<0.040	<0.040	<0.040	<0.040	<0.040	0.042	<0.040	<0.040	<0.040	<0.040	≤ 0.5	
Escherichia coli	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Bacterii coliforme	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Enterococi	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Clostridium perfringens	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017
Ultima actualizare: 31.05.2021.



**COMPANIA DE UTILITĂȚI PUBLICE
DUNĂREA BRĂILA**

ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1
Tel.: 40-239-692900 ; Fax: 40-239-693209
J09/215/14.03.1995/; C.F.:RO7179966/10.04.1995
www.apabraila.ro; e-mail:dunarea@apabraila.ro



Certificat nr. 730C ISO 9001
Certificat nr. 388M ISO 14001
Certificat nr. 006AM ISO 37001
Certificat nr. 269HS OHSAS 18001

**PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE GROPENI
MAI 2021**

Denumire indicatori de calitate	UM	Valori obtinute					Limite admise conform Legii 458/2002 republicata
		Punct de recoltare nr.					
		1	2	3	4	5	
		Loc. Valea Canepii	Loc. Perisoru	Loc. Urleasca	Loc. Bratesu Vechi	Loc. Gavani	
PH	unit de pH	8.1	8.1	8.2	8.1	8	6.5 ÷ 9.5
Conductivitate	μS/cm	446	434	436	433	413	≤ 2500
Turbiditate	grade NTU	0.53	0.85	0.62	0.68	0.75	≤ 5
Clor rezidual liber	mg/l	0.37	0.44	0.50	0.17	0.10	≥0.1 ÷ ≤0.5
Oxidabilitate	mgO2/l	1.10	0.98	1.04	1.24	1.23	≤ 5
Aluminiu	μg/l	134	158	155	147	110	≤ 200
Amoniu	mg/l	<0.060	<0.060	<0.060	0.139	<0.060	≤ 0.5
Nitrati	mg/l	5.097	4.256	3.889	3.952	3.722	≤ 50
Nitriti	mg/l	<0.040	<0.040	<0.040	<0.040	<0.040	≤ 0.5
Escherichia coli	ufc/100ml	0	0	0	0	0	0
Bacterii coliforme	ufc/100ml	0	0	0	0	0	0
Enterococi	ufc/100ml	0	0	0	0	0	0
Clostridium perfringens	ufc/100ml	0	0	0	0	0	0
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probe de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017 .
Ultima actualizare: 31.05.2021.



**COMPANIA DE UTILITĂȚI PUBLICE
DUNĂREA BRĂILA**
ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1
Tel.: 40-239-692900 ; Fax: 40-239-693209
J09/215/14.03.1995/; C.F.:RO7179966/10.04.1995
www.apabraila.ro; e-mail:dunarea@apabraila.ro



Certificat nr. 730C ISO 9001
Certificat nr. 388M ISO 14001
Certificat nr. 006AM ISO 37001
Certificat nr. 269HS OHSAS 18001

PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE ROSIORI

MAI 2021

Denumire indicatori de calitate	UM	Valori obtinute	Limite admise conform Legii 458/2002 republicata
		Punct de recoltare nr. 1	
		Loc. Florica	
PH	unit de pH	6.8	6.5 ÷ 9.5
Conductivitate	μS/cm	969	≤ 2500
Turbiditate	grade NTU	0.54	≤ 5
Clor rezidual liber	mg/l	0.18	≥0.1 ÷ ≤0.5
Oxidabilitate	mgO ₂ /l	<0.52	≤ 5
Fier	μg/l	60	≤ 200
Mangan	μg/l	<14	≤ 50
Duritate	°G	12.23	≥ 5
Amoniu	mg/l	<0.060	≤ 0.5
Nitrati	mg/l	31.120	≤ 50
Nitriti	mg/l	<0.040	≤ 0.5
Escherichia coli	ufc/100ml	0	0
Bacterii coliforme	ufc/100ml	0	0
Enterococi	ufc/100ml	0	0
Clostridium perfringens	ufc/100ml	-	0
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017 .
Ultima actualizare: 31.05.2021.



**COMPANIA DE UTILITĂȚI PUBLICE
DUNĂREA BRĂILA**
ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1
Tel.: 40-239-692900 ; Fax: 40-239-693209
J09/215/14.03.1995/; C.F.:RO7179966/10.04.1995
www.apabraila.ro; e-mail:dunarea@apabraila.ro



Certificat nr. 730C ISO 9001
Certificat nr. 388M ISO 14001
Certificat nr. 006AM ISO 37001
Certificat nr. 269HS OHSAS 18001

PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE VICTORIA

MAI 2021

Denumire indicatori de calitate	UM	Valori obtinute	Limite admise conform Legii 458/2002 republicata
		Punct de recoltare nr. 1	
		Loc. Victoria	
PH	unit de pH	7.4	6.5 ÷ 9.5
Conductivitate	μS/cm	1884	≤ 2500
Turbiditate	grade NTU	0.770	≤ 5
Clor rezidual liber	mg/l	0.10	≥0.1 ÷ ≤0.5
Oxidabilitate	mgO2/l	0.98	≤ 5
Fier	μg/l	50	≤ 200
Mangan	μg/l	<14	≤ 50
Duritate	°G	28.95	≥ 5
Amoniu	mg/l	<0.060	≤ 0.5
Nitrati	mg/l	0.249	≤ 50
Nitriti	mg/l	<0.040	≤ 0.5
Escherichia coli	ufc/100ml	0	0
Bacterii coliforme	ufc/100ml	0	0
Enterococi	ufc/100ml	0	0
Clostridium perfringens	ufc/100ml	-	0
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017 .
Ultima actualizare: 31.05.2021.