



COMPANIA DE UTILITĂȚI PUBLICE  
DUNĂREA BRĂILA

ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1  
Tel.: 40-239-692900 ; Fax: 40-239-693209  
J09/215/14.03.1995/; C.F.:RO7179966/10.04.1995  
www.apabraila.ro; e-mail:dunarea@apabraila.ro



Cod F 409

ISO 9001 Certificat nr. 730C  
ISO 14001 Certificat nr. 388M  
ISO 45001 Certificat nr. 269HS  
ISO 37001 Certificat nr. 006AM

PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE BRAILA

MAI 2022

Denumire indicatori de calitate	UM	Valori obtinute													Limite admise conform Legii 458/2002 republicata	
		Punct de recoltare nr.														
		1	2	3	4	5	6	7	8	9	10	11	12	13		
PH	unit de pH	7.7	7.8	7.4	7.5	7.7	8	7.9	7.8	7.7	7.7	7.7	7.6	7.4	6.5 ÷ 9.5	
Conductivitate	µS/cm	403	403	407	409	405	407	419	418	403	407	401	398	399	≤ 2500	
Turbiditate	grade NTU	0.48	0.35	0.52	0.54	0.63	0.43	0.81	0.60	0.48	0.56	0.51	0.42	0.45	≤ 5	
Clor rezidual liber	mg/l	0.11	0.26	0.49	0.36	0.45	0.33	0.12	0.37	0.46	0.24	0.18	0.39	0.31	≥0.1 ÷ ≤0.5	
Oxidabilitate	mgO <sub>2</sub> /l	0.58	1.04	0.84	0.71	1.35	1.04	0.65	1.16	0.9	1.03	0.97	0.81	1.04	≤ 5	
Aluminiu	µg/l	49	52	70	69	62	93	82	90	63	70	50	51	49	≤ 200	
Amoniu	mg/l	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	≤ 0.5	
Nitrati	mg/l	4.027	3.786	2.915	3.017	3.217	2.946	2.853	2.776	2.430	2.576	3.642	3.678	3.691	≤ 50	
Nitriti	mg/l	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	≤ 0.5	
Escherichia coli	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Bacterii coliforme	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Enterococi	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Clostridium perfringens	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017

Ultima actualizare: 31.05.2022.



COMPANIA DE UTILITĂȚI PUBLICE  
DUNĂREA BRĂILA

ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1  
Tel.: 40-239-692900 ; Fax: 40-239-693209  
J09/215/14.03.1995; C.F.:RO7179966/10.04.1995  
www.apabraila.ro; e-mail:dunarea@apabraila.ro



Cod F 409

ISO 9001 Certificat nr. 730C  
ISO 14001 Certificat nr. 388M  
ISO 45001 Certificat nr. 269HS  
ISO 37001 Certificat nr. 006AM

PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE GROPENI  
MAI 2022

Denumire indicatori de calitate	UM	Valori obtinute					Limite admise conform Legii 458/2002 republicata
		Punct de recoltare nr.					
		1	2	3	4	5	
		Loc. Perisoru	Loc. Urleasca	Loc. Bratesu Vechi	Loc. Gavani	Loc. Valea Canepii	
PH	unit de pH	7.5	7.5	7.6	7.9	7.6	6.5 ÷ 9.5
Conductivitate	μS/cm	404	399	402	396	408	≤ 2500
Turbiditate	grade NTU	0.51	0.57	1.6	0.78	0.54	≤ 5
Clor rezidual liber	mg/l	0.49	0.12	0.20	0.15	0.49	≥0.1 ÷ ≤0.5
Oxidabilitate	mgO <sub>2</sub> /l	0.52	<0.52	1.03	0.71	0.96	≤ 5
Aluminiu	μg/l	77	89	136	81	82	≤ 200
Amoniu	mg/l	<0.060	<0.060	<0.060	<0.060	<0.060	≤ 0.5
Nitrati	mg/l	5.192	5.261	3.396	2.691	4.564	≤ 50
Nitriti	mg/l	<0.038	<0.038	<0.038	<0.038	<0.038	≤ 0.5
Escherichia coli	ufc/100ml	0	0	0	0	0	0
Bacterii coliforme	ufc/100ml	0	0	0	0	0	0
Enterococi	ufc/100ml	0	0	0	0	0	0
Clostridium perfringens	ufc/100ml	0	0	0	0	0	0
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017 .

Ultima actualizare: 31.05.2022.



**COMPANIA DE UTILITĂȚI PUBLICE  
DUNĂREA BRĂILA**

ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1  
Tel.: 40-239-692900 ; Fax: 40-239-693209  
J09/215/14.03.1995/; C.F.:RO7179966/10.04.1995  
www.apabraila.ro; e-mail:dunarea@apabraila.ro



**Cod F 409**

ISO 9001 Certificat nr. 730C  
ISO 14001 Certificat nr. 388M  
ISO 45001 Certificat nr. 269HS  
ISO 37001 Certificat nr. 006AM

**PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE VICTORIA  
MAI 2022**

Denumire indicatori de calitate	UM	Valori obtinute	Limite admise conform Legii 458/2002 republicata
		Punct de recoltare nr.	
		1	
		Loc. Victoria	
PH	unit de pH	7.4	6.5 ÷ 9.5
Conductivitate	µS/cm	1884	≤ 2500
Turbiditate	grade NTU	0.31	≤ 5
Clor rezidual liber	mg/l	0.20	≥0.1 ÷ ≤0.5
Oxidabilitate	mgO2/l	<0.52	≤ 5
Fier	µg/l	10	≤ 200
Mangan	µg/l	<14	≤ 0.50
Amoniu	mg/l	0.213	≤ 0.5
Nitrati	mg/l	0.315	≤ 50
Nitriti	mg/l	<0.038	≤ 0.5
Duritate	°G	28.72	≥ 5
Escherichia coli	ufc/100ml	0	0
Bacterii coliforme	ufc/100ml	0	0
Enterococi	ufc/100ml	0	0
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017 .

Ultima actualizare: 31.05.2022.



**COMPANIA DE UTILITĂȚI PUBLICE  
DUNĂREA BRĂILA**

ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1  
Tel.: 40-239-692900 ; Fax: 40-239-693209  
J09/215/14.03.1995; C.F.:RO7179966/10.04.1995  
www.apabraila.ro; e-mail:dunarea@apabraila.ro



**Cod F 409**

ISO 9001 Certificat nr. 730C  
ISO 14001 Certificat nr. 388M  
ISO 45001 Certificat nr. 269HS  
ISO 37001 Certificat nr. 006AM

**PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE ROSIORI  
MAI 2022**

Denumire indicatori de calitate	UM	Valori obtinute	Limite admise conform Legii 458/2002 republicata
		Punct de recoltare nr. 1	
		Loc. Florica	
PH	unit de pH	7.2	6.5 ÷ 9.5
Conductivitate	μS/cm	1346	≤ 2500
Turbiditate	grade NTU	0.36	≤ 5
Clor rezidual liber	mg/l	0.2	≥0.1 ÷ ≤0.5
Oxidabilitate	mgO2/l	0.64	≤ 5
Fier	μg/l	<10	≤ 200
Mangan	μg/l	<14	≤ 0.50
Amoniu	mg/l	<0.060	≤ 0.5
Nitrati	mg/l	2.732	≤ 50
Nitriti	mg/l	<0.038	≤ 0.5
Duritate	°G	13.69	≥ 5
Escherichia coli	ufc/100ml	0	0
Bacterii coliforme	ufc/100ml	0	0
Enterococi	ufc/100ml	0	0
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017 .

Ultima actualizare: 31.05.2022.