



PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE BRAILA

IULIE 2022

Denumire indicatori de calitate	UM	Valori obtinute													Limite admise conform Legii 458/2002 republicat a	
		Punct de recoltare nr.														
		1	2	3	4	5	6	7	8	9	10	11	12	13		
		Viziru III	Obor	Gara CFR	Panait Istrati	Concordia	Loc. Lacu Sarat	Loc. Chiscani	Loc. Silistea	Loc. Martacesti	Loc. Muchea	Loc. Tudor Vladimirescu	Loc. Scortaru Vechi	Loc. Comaneasca		
PH	unit de pH	7.6	7.7	7.8	7.8	7.8	7.7	7.7	7.9	8	8	7.9	7.9	7.9	6.5 ÷ 9.5	
Conductivitate	µS/cm	387	386	383	383	387	389	383	385	386	382	392	434	384	≤ 2500	
Turbiditate	grade NTU	0.41	0.44	0.57	0.39	0.46	0.52	0.7	0.93	0.57	0.43	0.60	0.95	0.34	≤ 5	
Clor rezidual liber	mg/l	0.29	0.13	0.44	0.24	0.12	0.14	0.24	0.16	0.18	0.14	0.15	0.14	0.19	≥0.1 ÷ ≤0.5	
Oxidabilitate	mgO2/l	1.23	1.1	1.16	1.16	1.23	1.16	1.1	1.1	1.1	1.16	1.1	1.16	1.22	≤ 5	
Aluminiu	µg/l	89	78	98	96	91	80	93	88	102	102	78	75	89	≤ 200	
Amoniu	mg/l	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	≤ 0.5	
Nitrati	mg/l	2.545	2.763	2.351	2.664	2.656	2.873	2.970	3.103	2.376	2.702	2.062	2.054	2.089	≤ 50	
Nitriti	mg/l	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	≤ 0.5	
Escherichia coli	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Bacterii coliforme	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Enterococi	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Clostridium perfringens	ufc/100ml	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017

Ultima actualizare: 31.07.2022.



COMPANIA DE UTILITĂȚI PUBLICE
DUNĂREA BRĂILA

ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1
Tel.: 40-239-692900 ; Fax: 40-239-693209
J09/215/14.03.1995/; C.F.:RO7179966/10.04.1995
www.apabraila.ro; e-mail:dunarea@apabraila.ro



Cod F 409

ISO 9001 Certificat nr. 730C
ISO 14001 Certificat nr. 388M
ISO 45001 Certificat nr. 269HS
ISO 37001 Certificat nr. 006AM

PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE GROPENI
IULIE 2022

Denumire indicatori de calitate	UM	Valori obtinute							Limite admise conform Legii 458/2002 republicata
		Punct de recoltare nr.							
		1	2	3	4	5	6	7	
		Loc. Lanurile	Loc. Ianca	Loc. Oprisenesti	Loc. Silistraru	Loc. Filipesti	Loc. Visani	Loc. Ramnicelu	
PH	unit de pH	7.9	7.7	7.9	7.9	7.9	8.1	7.9	6.5 ÷ 9.5
Conductivitate	µS/cm	360	361	367	362	358	361	351	≤ 2500
Turbiditate	grade NTU	0.96	0.81	0.74	0.52	0.86	0.84	0.65	≤ 5
Clor rezidual liber	mg/l	0.2	0.45	0.16	0.31	0.12	0.35	0.12	≥0.1 ÷ ≤0.5
Oxidabilitate	mgO ₂ /l	0.9	1.23	1.23	1.35	1.68	1.75	1.49	≤ 5
Aluminiu	µg/l	124	121	103	119	150	127	119	≤ 200
Amoniu	mg/l	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	<0.060	≤ 0.5
Nitrati	mg/l	2.697	3.620	3.325	3.641	2.238	2.408	1.879	≤ 50
Nitriti	mg/l	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	<0.038	≤ 0.5
Escherichia coli	ufc/100ml	0	0	0	0	0	0	0	0
Bacterii coliforme	ufc/100ml	0	0	0	0	0	0	0	0
Enterococi	ufc/100ml	0	0	0	0	0	0	0	0
Clostridium perfringens	ufc/100ml	0	0	0	0	0	0	0	0
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017 .

Ultima actualizare: 31.07.2022.



**COMPANIA DE UTILITĂȚI PUBLICE
DUNĂREA BRĂILA**

ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1
Tel.: 40-239-692900 ; Fax: 40-239-693209
J09/215/14.03.1995/; C.F.:RO7179966/10.04.1995
www.apabraila.ro; e-mail:dunarea@apabraila.ro



Cod F 409

ISO 9001 Certificat nr. 730C
ISO 14001 Certificat nr. 388M
ISO 45001 Certificat nr. 269HS
ISO 37001 Certificat nr. 006AM

**PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE VICTORIA
IULIE 2022**

Denumire indicatori de calitate	UM	Valori obtinute	Limite admise conform Legii 458/2002 republicata
		Punct de recoltare nr.	
		1	
Loc. Baraganu			
PH	unit de pH	7.5	6.5 ÷ 9.5
Conductivitate	μS/cm	1867	≤ 2500
Turbiditate	grade NTU	0.43	≤ 5
Clor rezidual liber	mg/l	0.12	≥0.1 ÷ ≤0.5
Oxidabilitate	mgO2/l	1.03	≤ 5
Fier	μg/l	36	≤ 200
Mangan	μg/l	<14	≤ 0.50
Amoniu	mg/l	0.207	≤ 0.5
Nitrati	mg/l	1.687	≤ 50
Nitriti	mg/l	0.140	≤ 0.5
Duritate	°G	30.29	≥ 5
Escherichia coli	ufc/100ml	0	0
Bacterii coliforme	ufc/100ml	0	0
Enterococi	ufc/100ml	0	0
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017 .

Ultima actualizare: 31.07.2022.



**COMPANIA DE UTILITĂȚI PUBLICE
DUNĂREA BRĂILA**

ROMÂNIA, 810140 BRĂILA, str.Piața Uzinei nr.1
Tel.: 40-239-692900 ; Fax: 40-239-693209
J09/215/14.03.1995/; C.F.:RO7179966/10.04.1995
www.apabraila.ro; e-mail:dunarea@apabraila.ro



Cod F 409

ISO 9001 Certificat nr. 730C
ISO 14001 Certificat nr. 388M
ISO 45001 Certificat nr. 269HS
ISO 37001 Certificat nr. 006AM

**PARAMETRII DE CALITATE AI APEI POTABILE ZONA DE APROVIZIONARE ROSIORI
IULIE 2022**

Denumire indicatori de calitate	UM	Valori obtinute	Limite admise conform Legii 458/2002 republicata
		Punct de recoltare nr. 1 Loc. Coltea	
PH	unit de pH	7	6.5 ÷ 9.5
Conductivitate	μS/cm	1032	≤ 2500
Turbiditate	grade NTU	0.51	≤ 5
Clor rezidual liber	mg/l	0.12	≥0.1 ÷ ≤0.5
Oxidabilitate	mgO2/l	0.71	≤ 5
Fier	μg/l	130	≤ 200
Mangan	μg/l	<14	≤ 0.50
Amoniu	mg/l	0.068	≤ 0.5
Nitrati	mg/l	50.353	≤ 50
Nitriti	mg/l	<0.038	≤ 0.5
Duritate	°G	7.97	≥ 5
Escherichia coli	ufc/100ml	0	0
Bacterii coliforme	ufc/100ml	0	0
Enterococi	ufc/100ml	0	0
Nr.de colonii la 22°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala
Nr.de colonii la 37°C	ufc/ml	Nicio modificare anormala	Nicio modificare anormala

CONCLUZII: Probele de apa sunt conforme cu Legea 458/2002 republicata modificata si completata cu Ordonanta nr. 22/2017 .
Ultima actualizare: 31.07.2022.